

Tag Colors

All electrical equipment including those kept in sheds and site offices must be tested and tagged in accordance to the Code of Practice – Electrical practices for construction and a durable non metallic tag must be applied. A different colour tag must be used for each month as follows:

January - Red

February - Blue

March - Orange

April - Green

May - White

June - Yellow

July - Blue

August - Green

September - Red

October - Yellow

November - Orange

December – White

The tag must include the date of the inspection, the plant number or inspection number of the item inspected, the name of the testing company